

Substance	Unit of Measure	Year	MCL	Average Level Detected	Minimum - Maximum Level Detected	MCLG	In Compliance	Typical Sources
Radioactive Contaminants (Regulated at the Water Plant)								
Gross Beta	pCi/L	2015	50	4	4 - 4	0	Yes	Decay of natural and man-made deposits.
Inorganic Contaminants (Regulated at the Water Plant)								
Fluoride	ppm	2015	4	0.21	0.2 - 0.22	4	Yes	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Arsenic	ppb	2015	10	3	2.2 - 3.8	0	Yes	Erosion of natural deposits; runoff from orchards; runoff from glass, and electronics production wastes.
Barium	ppm	2015	2	0.09	0.0827 - 0.0953	2	Yes	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Selenium	ppb	2015	50	5.55	4.3 - 6.8	50	Yes	Erosion of natural deposits.
Maximum Residual Disinfectant Level								
Chlorine Residual	ppm	2017	4.0	1.5	1.25 - 1.64	4.0	Yes	Water additive used to control microbes.
Lead and Copper (Regulated at Customers Tap)								
Lead	ppb	2017	0	15	0	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits.
Copper	ppm	2017	0.056	1.3	0	1.3	Yes	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

* All levels detected were below the MCLs.